PRODUCT PERFORMANCE REPORT

Document ID 1534343411
Issued on August 15th, 2018

PROJECT IDENTIFICATION

- This product performance report is delivered for:

Name	**Viacom VS**
Company	**Viacom VS**
Project reference	**Fujitsu Website**
Project location	**Serbia and Montenegro**

PRODUCT IDENTIFICATION

Certification Diploma N°	**94.01.198**
Brand	**FUJITSU**
Range	**ASY**L**
Product type	**Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
Product reference	**AOYG24LFCC / ASYG24LFCC**

Important notice:

I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at http://www.eurovent-certification.com

II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	68	dB(A)
LwI1 env	64	dB(A)
Bivalent Point		
Tbiv	-7	Â°C
COP @ Tbiv	2.19	
Ph TBiv	6.28	kW
General		
Mounting	Wall mounted	
MPS	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
Heating 14511		
Ph @+7	8.0	kW
COP @+7	3.62	
Heating Average Climate		
Pdesignh	7.1	kW
SCOP	3.8	
SCOP Class	A	
Qhe	2610.0	kWh/annum
Pck		
Pck	17.0	W
Poffc		

PRODUCT PERFORMANCE REPORT

Document ID 1534343411
Issued on August 15th, 2018

FEATURE	VALUE	UNIT
Poff	6.0	W
Poffh		
Poffh	15.0	W
Psbc		
Psb	6.0	W
Ptoc		
Pto	17.0	W
Seasonal Efficiency in Cooling		
Pdesignc	7.1	kW
SEER	6.11	
SEER Class	A++	
Qce	406.0	kWh/annum
Thermal		
EER @+35	3.23	
TOL Runing Test		
TOL	-15.0	Â°C
COP @ TOL	2.08	
Ph @ TOL	6.07	kW